

March 06, 2026

Attention: Jim Knockeart
CRANE INSTRUMENTATION SAMPLING PFT CORP
405 CENTURA COURT
SPARTANBURG, SC 29303

The design submission, Tracking Number 2026-00806, originally received on February 10, 2026 was surveyed and accepted for registration as follows:

CRN :	0C26046.2	Accepted on:	March 06, 2026
Reg Type:	NEW DESIGN	Expiry Date:	March 06, 2036
Document No.	6300 Series, ER-ValveS6300_CRN_RevA		
Fitting type:	Valves sizes 1/4" & 1/2"		

Description	MAWP	Design Temperature
See scope for rating		

The registration is conditional on your compliance with the following notes:

As indicated on AB-41 Statutory Declaration or AB-351 Declaration of Conformity form and submitted documentation, the code of construction are ASME B31.1 and ASME B31.3.

- It is our understanding that the fitting(s), included as the scope of this submission, that is(are) subject to the Safety Codes Act shall comply with the requirements of the indicated Standard or Code of Construction on the AB-41 Statutory Declaration or AB-351 Declaration of Conformity as supported by the attached data which identifies the dimensions, materials of construction, press./temp. ratings and the basis for such ratings, and the identification marking of the fittings.*
- This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-41 Statutory Declaration or AB-351 Declaration of Conformity form.*
- This registration is valid only until the indicated expiry date and only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency, and maintains a valid Certification of Authorization Permit if required by the jurisdiction where manufacturing takes place, until that date.*
- Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.*

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any questions don't hesitate to contact me by phone at (587) 686-9318 or fax (780) 437-7787 or e-mail Grynchuk@absa.ca.

Sincerely,



GRYNCHUK, MILLA, P. Eng.
DOP Cert. No. D00005217

STATUTORY DECLARATION
Registration of Fittings
Single or Multiple Fitting Designs within one Fitting Category

I, JIM KNOCKEART, ENGINEERING MANAGER
(name of applicant) (position title) (must be in a position of authority)
of CRANE INSTRUMENTATION & SAMPLING PFT CORP.
(name of manufacturer)
located at 405 CENTURA COURT, SPARTANBURG, SC 29303 USA
(plant address)

In this space, show facsimile of manufacturer's logo or trademark as it will appear on the fitting.

CRANE

HOKI

do solemnly declare that the fittings listed hereunder, which are subject to the Safety Codes Act
(select only one)

- ☒ comply with the requirements of ASME B31.1 & ASME B31.3 KR 20 which specifies the dimensions,
(title of recognized North American Standard)
materials of construction, pressure/temperature ratings and identification marking of the fittings, or
- ☐ are not covered by the provisions of a recognized North American standard and are therefore
manufactured to comply with _____ as supported by the
(title of code of construction or other applicable document)
attached data which identifies the dimensions, materials of construction, pressure/temperature ratings
and the basis for such ratings, and the identification marking of the fittings.

I further declare that the manufacture of these fittings is controlled by a quality control program which has been verified as described in the below Table as being suitable for the manufacturing of these fittings to the stated standard, regulation, code, guideline or other applicable document. The fittings covered by the declaration for which I seek registration are as provided in the Supplementary Sheet(s) attached.

Quality Program Verification and Manufacturing Sites


A copy of the Quality Certificate from each manufacturing site must be included

Item #	Product Description, Model or Series	Quality Program	Scope of Certification	Expiry Date	Verifying Organization	Location(s) Plant Name and address
1.	VALVES PER SCOPE OF REGISTRATION	ISO 9001:2015	DESIGN MANUFACTURE & ASSEMBLY OF VALVES	2026-10-21	INTERTEK TESTING SERVICES	405 CENTURA COURT, SPARTANBURG, SC
2.						

In support of this application, the following information, calculations and/or test data are attached:

SCOPE OF REGISTRATION, BURST TEST REPORTS, CALCULATIONS, QC CERTIFICATE,

ER-VALVES6300-CRN (REV -)


(Signature of the Declarer)

2/6/2026
(Date)

DECLARED before me at Spartanburg in the State of South Carolina
(city) (province, territory, or state)

this 6th day of February, 2026
(Month) (Year)

(print) Frances C. Pouncey
(a Commissioner of Oaths or Notary Public)

(sign) 
(a Commissioner of Oaths or Notary Public)

02/23/2034
(expiry date (mm/dd/yy))



Frances C. Pouncey
NOTARY PUBLIC, STATE OF SOUTH CAROLINA
My Commission Expires 02/23/2034

Commissioner of Oaths / Notary Public in and for: South Carolina
(province, territory, or state)

For ABSA Office Use Only:

NOTES: _____

To the best of my knowledge and belief, the application meets the requirements of the Safety Codes Act and CSA Standard B51, Part 1, Clause 4.2, and is accepted for registration in Category _____.


CRN: _____

Registered Date: _____

Expiry Date: 2036.03.06

Signature: _____
(Signature of the Administrator/SCO)

The information you provide is necessary only for the administration of the programs as required by the Alberta Safety Codes Act and Regulations in the Pressure Equipment Discipline



This stamp and signature have been affixed electronically to this registered design as required by Section 20(1) of the Pressure Equipment Safety Regulation, in accordance with the Electronic Transactions Act.

 ER-Valves6300_CRN	Engineering Report Title Qualification of Hoke Valves by Burst Test and Similarity	REV. DATE: PAGE:	A 26-Feb-2026 63 OF 63
--	---	------------------------	------------------------------

SCOPE OF REGISTRATION							
				Maximum Allowable Working Pressure			
Hoke Valve Series	Main Pressure Bearing Components	Conn. Sizes	Min. Design Metal Temp. (MDMT)	MDMT $\leq T \leq 100^{\circ}\text{F}$	At Max. Temp.	Assembly drawings	Design Code of Construction
6300	ASTM A182 / ASME SA-182 F316/L	F4, G4, G6, G8, G2, G6MM, G8MM, G12MM,	-60°F	5000 PSIG	4995 PSIG @ 450° F	632[] [] [], 632[] F4[], 632[] G4[], 632[] G8[].	ASME B31.1 ASME B31.3



This stamp and signature have been affixed electronically to this registered design as required by Section 20(1) of the Pressure Equipment Safety Regulation, in accordance with the Electronic Transactions Act.