



REGISTRATION OF A PRESSURE FITTING DESIGN

March 27, 2026

ABSA
9410-20 Avenue
Edmonton, AB
Canada
T6N 0A4

Attention: Kristine Trepanier

File Number: 104583

Re: Manufacturer: Crane Instrumentation and Sampling PFT Corp.
Item: Series 6300 Hoke Valves
Catalog or Drawing: Scope of Registration ER-Valves6300_CRN Rev. A (26-Feb-2026)

TSASK Codes and Standards Compliance has registered the design listed above in accordance with The Boiler and Pressure Vessel Act and Regulations and CSA B51. The Canadian Registration Number (CRN) is:

OC26046.23

Expiry Date: 2036-03-06

Please note that every fitting shall be constructed in strict accordance with the registered design.

Fitting registrations are required to be resubmitted for validation after ten (10) years from the registration date in accordance with CSA B51, Clause 4.2.1.

Should you require anything further, please do not hesitate to contact the Codes and Standards Compliance Office at your convenience.

Yours truly,

Athan Syrgiannis, P.Eng.

Codes and Standards Compliance

Remarks:

A valid quality control program must be maintained at the production facility for the fitting registration to remain valid until the expiry date.

Conditional upon compliance with the notes on the original ABSA registration.

STATUTORY DECLARATION
Registration of Fittings
Single or Multiple Fitting Designs within one Fitting Category

I, JIM KNOCKEART, ENGINEERING MANAGER
(name of applicant) (position title) (must be in a position of authority)
of CRANE INSTRUMENTATION & SAMPLING PFT CORP.
(name of manufacturer)
located at 405 CENTURA COURT, SPARTANBURG, SC 29303 USA
(plant address)

In this space, show facsimile of
manufacturer's logo or trademark
as it will appear on the fitting.

CRANE

HOKÉ

do solemnly declare that the fittings listed hereunder, which are subject to the Safety Codes Act
(select only one)

- ☒ comply with the requirements of ASME B31.1 & ASME B31.3 ²⁰²⁴ ~~KR-20~~ which specifies the dimensions,
(title of recognized North American Standard)
materials of construction, pressure/temperature ratings and identification marking of the fittings, or
- ☐ are not covered by the provisions of a recognized North American standard and are therefore
manufactured to comply with _____ as supported by the
(title of code of construction or other applicable document)
attached data which identifies the dimensions, materials of construction, pressure/temperature ratings
and the basis for such ratings, and the identification marking of the fittings.

I further declare that the manufacture of these fittings is controlled by a quality control program which has
been verified as described in the below Table as being suitable for the manufacturing of these fittings to the
stated standard, regulation, code, guideline or other applicable document. The fittings covered by the
declaration for which I seek registration are as provided in the Supplementary Sheet(s) attached.

Quality Program Verification and Manufacturing Sites


A copy of the Quality Certificate from each manufacturing site must be included

Item #	Product Description, Model or Series	Quality Program	Scope of Certification	Expiry Date	Verifying Organization	Location(s) Plant Name and address
1.	VALVES PER SCOPE OF REGISTRATION	ISO 9001:2015	DESIGN MANUFACTURE & ASSEMBLY OF VALVES	2026-10-21	INTERTEK TESTING SERVICES	405 CENTURA COURT, SPARTANBURG, SC
2.						

In support of this application, the following information, calculations and/or test data are attached:

SCOPE OF REGISTRATION, BURST TEST REPORTS, CALCULATIONS, QC CERTIFICATE,

ER-VALVES6300-CRN (REV -)


(Signature of the Declarer)

2/6/2026
(Date)

DECLARED before me at Spartanburg in the State of South Carolina
(city) (province, territory, or state)

this 6th day of February, 2026
(Month) (Year)

(print) Frances C. Pouncey
(a Commissioner of Oaths or Notary Public)

(sign) 
(a Commissioner of Oaths or Notary Public)

02/23/2034
(expiry date (mm/dd/yy))



Frances C. Pouncey
NOTARY PUBLIC, STATE OF SOUTH CAROLINA
My Commission Expires 02/23/2034

Commissioner of Oaths / Notary Public in and for: South Carolina
(province, territory, or state)

For ABSA Office Use Only:

NOTES: _____

To the best of my knowledge and belief, the application meets the requirements of the Safety Codes Act and CSA Standard B51, Part 1, Clause 4.2, and is accepted for registration in Category _____.

CRN: _____

Registered Date: _____

Expiry Date: _____

Signature: _____

(Signature of the Administrator/SCO)

The information you provide is necessary only for the administration of the programs as required by the Alberta Safety Codes Act and Regulations in the Pressure Equipment Discipline



Registration No. 0C26046.23

File No. 104583

Registered

Date: March 27, 2026

Expiry Date: March 6, 2036

Codes & Standards Compliance Office

Table 1** Scope of Fitting Designs

Item #	Primary Pressure Bearing / Retaining Component	Material of Construction	Port Connections and Size Range	MDMT	Rated Pressure		Pressure Class(es) / Schedule(s)	Design Code(s) of Construction	Reference Catalogue (pages) or Drawing(s)
					At Ambient Temperature	At Maximum Temperature			

Table 2 Additional Scope Information

List/Attach Additional Detail and References (Product Configurations, Options, Illustrations, etc.)
Example:
Series X Options

** For additional alternatives of Table 1, refer to Form AB-41a, Guide for Completing Form AB-41

 ER-Valves6300_CRN	Engineering Report Title Qualification of Hoke Valves by Burst Test and Similarity	REV. DATE: PAGE:	A 26-Feb-2026 63 OF 63
--	---	---	---

SCOPE OF REGISTRATION							
				Maximum Allowable Working Pressure			
Hoke Valve Series	Main Pressure Bearing Components	Conn. Sizes	Min. Design Metal Temp. (MDMT)	MDMT $\leq T \leq 100^{\circ}\text{F}$	At Max. Temp.	Assembly drawings	Design Code of Construction
6300	ASTM A182 / ASME SA-182 F316/L	F4, G4, G6, G8, G2, G6MM, G8MM, G12MM,	-60°F	5000 PSIG	4995 PSIG @ 450° F	632[] [] [], 632[] F4[], 632[] G4[], 632[] G8[].	ASME B31.1 ASME B31.3



 Technical Safety Authority of Saskatchewan	
Registration No.	0C26046.23
File No.	104583
	Registered
Date:	March 27, 2026
Expiry Date:	March 6, 2036
Codes & Standards Compliance Office	